



NOTES:

- 1) MINIMUM TRENCH WIDTH FOR LINES 16" DIA AND SMALLER:
PIPE DIAMETER + 12".
MINIMUM TRENCH WIDTH FOR LINES LARGER THAN 16" DIA:
PIPE DIAMETER + 18".
- 2) FOR PIPES GREATER THAN 16" DIA, SPECIFICATIONS SHALL BE MADE ON A PROJECT SPECIFIC BASIS.
- 3) ADD TRACER WIRE FOR PVC LINES. AFFIX WIRE TO TOP OF PIPE ON CENTER LINE.
- 4) FOR ALL PIPES, PLACE MARKER BALLS OR DISCS PER THAT DETAIL.
- 5) MIN COVER TO BE 36" UNLESS LESSER COVER IS APPROVED BY PSA DUE TO SITE CONDITIONS. IN NO CASE SHALL COVER BE LESS THAN 30".
- 6) 4" MIN IN SOIL, 6" MIN IN ROCK, 18" MIN OR AS OTHERWISE SPECIFIED WHEN UNSUITABLE MATERIAL ENCOUNTERED.
- 7) FOR 2" DIA AND LESS PVC OR HDPE,; #10 STONE DUST.
FOR 4" TO 16" DIA PVC OR DI; #57 OR #68 STONE.
FOR LARGER THAN 16" DIA; PROJECT SPECIFIC BASIS



PIPE BEDDING FOR PRESSURIZED LINES

EFFECTIVE
05/2023

DETAIL NO.
106