



NOTES:

- 1) MINIMUM TRENCH WIDTH FOR LINES 16" DIA AND SMALLER:
PIPE DIAMETER + 12".
MINIMUM TRENCH WIDTH FOR LINES LARGER THAN 16" DIA:
PIPE DIAMETER + 18".
- 2) FOR PIPES GREATER THAN 16" DIA, SPECIFICATIONS SHALL
BE MADE ON A PROJECT SPECIFIC BASIS.
- 3) AFFIX TRACER WIRE TO TOP OF PIPE ON CENTER LINE.
- 4) MIN COVER TO BE 36" UNLESS LESSER COVER IS
APPROVED BY PSA DUE TO SITE CONDITIONS. IN NO CASE
SHALL COVER BE LESS THAN 30".
- 5) 4" MIN IN SOIL, 6" MIN IN ROCK, 18" MIN OR AS OTHERWISE
SPECIFIED WHEN UNSUITABLE MATERIAL ENCOUNTERED.
- 6) FOR 2" DIA AND LESS PVC OR HDPE,; #10 STONE DUST.
FOR 4" TO 16" DIA PVC OR DI; #57 OR #68 STONE.
FOR LARGER THAN 16" DIA; PROJECT SPECIFIC BASIS