



NOTES:

- 1) MINIMUM TRENCH WIDTH FOR LINES 16" DIA AND SMALLER:
PIPE DIAMETER + 12".
MINIMUM TRENCH WIDTH FOR LINES LARGER THAN 16" DIA:
PIPE DIAMETER + 18".
- 2) FOR PIPES GREATER THAN 24" DIA, SPECIFICATIONS SHALL
BE MADE ON A PROJECT SPECIFIC BASIS.
- 3) ADD TRACER WIRE FOR ALL SANITARY LATERALS TO
PROPERTY LINE CLEANOUT.
- 4) MAIN LINE COVER TO BE AS CALLED OUT ON PROFILE
SHEETS.
- 5) 6" MIN IN SOIL OR ROCK, 18" MIN OR AS OTHERWISE
SPECIFIED WHEN UNSUITABLE MATERIAL ENCOUNTERED.
- 6) FOR 6" DIA AND LESS PVC OR DI; #10 STONE DUST.
FOR 8" TO 24" DIA PVC OR DI; #57 OR #68 STONE.
FOR LARGER THAN 24" DIA; PROJECT SPECIFIC BASIS

PIPE BEDDING FOR GRAVITY LINES



EFFECTIVE
05/2023

DETAIL NO.
107