



A	B
2"	2"
3"	2"
4"	3" OR 4"
6"	4" OR 6"
8"	4", 6", OR 8"
10"	6", 8", OR 10"
12"	8", 10", OR 12"
14"	10", 12", OR 14"
16"	12", 14", OR 16"

A = MAIN SIZE
B = CHECK VALVE AND GATE VALVE SIZE

NOTES:

- 1) THIS DEVICE IS TO BE USED FOR FILLING, FLUSHING, PRESSURE TESTING, AND CHLORINATION OF ALL WATERLINES INSTALLED ON PSA SYSTEMS. NO EXCEPTIONS ARE TO BE MADE.
- 2) FITTINGS AND VALVES TO BE RATED FOR TEST PRESSURE UP TO 350 PSI. PER AWWA C111, THIS MAY REQUIRE THE USE OF SPECIAL GASKETS. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO OBTAIN ADEQUATE FITTINGS FOR THE PROJECT.
- 3) MANUFACTURED DOUBLE CHECKS MAY BE USED IN LIEU OF FLANGED FITTINGS AND VALVES PROVIDED THEY ARE FLANGED AND THE TEST PRESSURE IS LESS THAN 175 PSI.
- 4) CONTRACTOR IS RESPONSIBLE FOR COORDINATING LINE FILLING/TESTING WITH THE PSA AND FOR COMPLYING WITH ALL PSA SPECIFICATIONS REGARDING TESTING AND SAMPLE COLLECTION.



WATERLINE FILL & TEST PROTECTION ASSEMBLY

EFFECTIVE
05/2023

DETAIL NO.
217