



NOTES:

- 1) THIS DETAIL IS TO ILLUSTRATE DROPS ON STANDARD MANHOLES. REFER TO MANHOLE DETAILS FOR ALL OTHER MANHOLE REQUIREMENTS.
- 2) WHERE "A" IS GREATER THAN OR EQUAL TO 2', USE DROP CONNECTION.
- 3) DROP PIPE TO BE CLASS 50 DI.
- 4) CONCRETE ENCASEMENT MAY BE ELIMINATED IF RESTRAINED JOINT PIPE AND FITTINGS ARE USED.
- 5) INCOMING LINE TO HAVE 2.0% MAX SLOPE.
- 6) MANHOLE PENETRATIONS TO BE BY CORE DRILL & APPROVED PIPE BOOT.



SEWER DROP MANHOLE

EFFECTIVE
05/2023

DETAIL NO.
305