



NOTES:

1. ALL CLEANOUT STACK PIPES SHALL BE 4" PRESSURE RATED, EITHER DR18 PVC OR CLASS 50 DI. ALL FITTINGS TO BE MJ DI.
2. ALL MAIN LINE TAPS ON EXISTING ACTIVE MAINS SHALL BE MADE BY THE PSA OR A PSA APPROVED CONTRACTOR.
3. PIPING ON PRIVATE SIDE OF CLEANOUT TO BE INSTALLED PER GOVERNING JURISDICTION REQUIREMENTS.
4. THE PROPERTY OWNER SHALL BE RESPONSIBLE FOR INSTALLING A GRINDER PUMP AS REQUIRED AND FOR MAINTENANCE THEREOF. THE PSA'S JURISDICTION BEGINS AT THE TEE CONNECTION ON THE CLEANOUT. ALL PIPING PRIOR TO THAT IS THE RESPONSIBILITY OF THE PROPERTY OWNER.
5. INSTALL 4" MJ DI BENDS AS REQUIRED TO ENSURE LATERAL CONNECTION TO MAIN AT GRADE EQUAL TO OR GREATER THAN 1/4" PER 1'-0". MINIMIZE NUMBER OF FITTINGS.
6. MARKING TAPE, TRACER WIRE, AND MARKING BALLS/DISCS ARE TO BE PLACED ALONG ALL SEWER LATERALS.



PRIVATE GRINDER PUMP LATERAL CONNECTION

EFFECTIVE
07/2024

DETAIL NO.
311