



NOTES:

- 1) THIS DETAIL IS FOR FORCEMAIN TERMINATIONS WHERE "A" IS GREATER THAN OR EQUAL TO 2'.
- 2) DROP PIPE TO BE CLASS 50 OR 52 DI. IF FORCEMAIN IS SUBJECT TO SEPTIC CONDITIONS, PIPE IS TO BE COATED WITH PROTECTO 401 OR EQUAL SULFIDE RESISTANT COATING.
- 3) CONCRETE ENCASEMENT MAY BE ELIMINATED IF RESTRAINED JOINT PIPE AND FITTINGS ARE USED.
- 4) MANHOLE PENETRATIONS TO BE BY CORE DRILL & APPROVED PIPE BOOT.
- 5) REFER TO OTHER MANHOLE DETAILS FOR ADDITIONAL REQUIREMENTS.



FORCEMAIN TERMINATION DROP STACK TYPE

EFFECTIVE
07/2024

DETAIL NO.
313