



NOTES:

- 1) VENT PIPING TO BE CLASS 53, RESTRAINED JOINT BELOW GRADE, FLANGED JOINT ABOVE GRADE.
- 2) PIPING ABOVE GRADE TO BE EPOXY COATED PER PSA STANDARDS.
- 3) WHERE VENT PIPE IS BELOW 100-YR FLOODPLAIN ELEVATION, INSTALL BALL FLOAT CHECK VALVE - WAGER MODEL 1700 STAINLESS STEEL OR APPROVED EQUAL.
- 4) PROVIDE STAINLESS STEEL INSECT SCREEN ON OUTLET OF 90° BEND BETWEEN FLANGES



# SEWER MANHOLE VENT

EFFECTIVE  
07/2024

DETAIL NO.  
317